GUJARAT TECHNOLOGICAL UNIVERSITY

BE - SEMESTER-VII(NEW) • EXAMINATION - WINTER 2016

Subject Code:2171910 Date:01/				
Subject Name:Power Plant Engineering Time:10.30 AM to 1.00 PM Instructions: Total Mar			Total Marks:	70
	1. 2. 3.	Attempt all questions. Make suitable assumptions wherever necessary. Figures to the right indicate full marks. Use of steam table and Mollier chart are allowed.		
Q.1	(a) (b)	Explain working of Bowl pulverizing mill with neat sketch. A 200 MW thermal power plant has peak load of 130 MW. supplies load to four town having their maximum demand of 25 MW and 45 MW. The annual load factor is 65%. Find: (i the plant (ii) Energy supplied per year (iii) Diversity factor (v) Plant capacity factor.	30 MW, 40 MW, Average load on	07 07
Q.2	(a) (b)	plain pressure-velocity compounding of impulse turbine with diagram. Draw general layout of modern thermal power plant. State desirable to control the super heat temperature. Explain desuperheate thod.		07 04 03
	(b)	Explain working of Schmidt-Hartmann boiler with neat sketch	1.	07
Q.3	(a)	Define critical pressure.		07
	(b)	Derive $\frac{P_2}{P_1} = \left(\frac{2}{n+1}\right)^{\frac{n}{n-1}}$; where P ₂ is throat pressure, P ₁ is inlet the index of isentropic expansion of steam through the nozzle. The pressure and temperature of steam entering the nozzle are and steam leave the nozzle at 1 bar. The diameter of the noz mm. Calculate the mass flow rate of steam in a nozzle and whis required?	e 12 bar and 200°C ezle at throat is 10	07
		OR	2.450	. –
Q.3	(a) (b) (c)	Steam issues from the nozzles at angle of 18 ⁰ at a velocity of 450 m/sec. the friction factor is 0.88. For a single stage turbine designed for maximum efficiency, determine (i) Blade velocity (ii) Moving blade angles for equi-angular blades (iii) blade efficiency (iv) stage efficiency if the nozzle efficiency is 95% (v) Power developed for a mass flow rate of steam of 4 kg/sec. Distinguish between force draught and induced draught. Explain Unit pulverized coal handling system with neat sketch.		07 03 04
Q.4	(a) (b)	In a condenser, vacuum reads 716 mm of Hg while barometer reads 756 mm of Hg. The temperature of condensate is 25°C. Determine (i) The pressure of the steam and air (ii) Mass of air per kg of steam (iii) The vacuum efficiency. Explain Zeolite ion exchange process for feed water treatment plant.		07 07
		OR		
Q.4	(a)	A gas turbine operates on Brayton cycle. The temperature rate 288 K. Find pressure ratio for maximum power output. Also efficiency, work ratio and power output, if the mass flow rate Take $C_p = 1.005 \ kJ/kg \ K$ and $\Upsilon = 1.4$ for compression and exp	determine thermal of air is 20 kg/sec. ansion process.	07
	(b)	Explain the parameters affected on work ratio in gas turbine p	ower plant.	07

http://www.gujaratstudy.com

Q.5	(a)	List the nuclear reactors. Explain working of Pressurized water reactor.	
	(b)	Explain construction and working of Turbojet.	07
		OR	
Q.5	(a)	Define blade efficiency and derive an expression for maximum blade efficiency for single stage impulse steam turbine.	07
	(b)	Derive an expression for air standard efficiency of ideal Bryton cycle in terms of pressure ratio. State the assumption made.	07